

SAFE DRINKING WATERNO. 202Date: 27/04/2026

It is certified that an inspection team headed by **UDAY CHAND RAM**, (Name of Officers with designation) from ASSISTANT ENGINEER, P.H. SUB DIVISION, **GAYAJI** (Name of department/Office) inspected the **JAY HIND PUBLIC SCHOOL**, **P.O- ZINDAPUR DISTRICT - GAYA JI (BIHAR) 824234** (Name & Address of the School) on 22.04.2026 and on the basis of Water Test Report (attached) bearing no. 13/2026.dated 27.04.2026 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till ONE YEAR.

Signature: 27/04/26Name: (UDAY CHAND RAM)

Designation: ASSISTANT ENGINEER

Name & Add. Of Department/

Office: P.H. SUB DIVISION,
GAYA JI WEST, GAYA JI

To,

JAY HIND PUBLIC SCHOOL, **VIGYAN NAGAR, GAYA DOBHI ROAD**,
P.O-ZINDAPUR, DISTRICT- GAYA JI
(BIHAR) 824234

(Name & Address of the Institution)

Kushno deo Prasad
Secretary
Jai Hind Public School
Vigyan Nagar, Bodh Gaya

Dr. S.K. Verma
Dr.S.K. Verma
Principal
Jai Hind Public School
Vigyan Nagar, Bodh Gay

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :		JAI HIND PUBLIC SCHOOL VIGYAN NAGAR GAYA DOBHI ROAD										Sample Received on : 22/04/26							
Sample no	Block Name	Panchayat Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+/-)	Remarks
1	Bodh Gaya	Bodh Gaya	Vigyan Nagar	-	0.39	550	375	144	46.49	6.8	51.98	172	0.45	7.37	-	-	20	Absent	
Reporting Date :	27.04.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
Permissible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	

* NR-No Relaxation, BDL-Below Detection Limit

जल नमूना का संग्रह दिनांक 22.04.26
पपु प्रशद द्वारा किया गया है।

P.H. Division, Gaya
Chemist
27.04.26

Koushno de Prasad
Secretary
Jai Hind Public School
Vigyan Nagar, Bodh Gaya

Vandana
07.09.2026
Dr. S. K. Verma
Principal
Jai Hind Public School
Vigyan Nagar, Bodh Gaya